

**Public Input Opportunity**

Your water board meets at  
12:00 pm on the Second  
Wednesday  
of every month at  
1300 Post Oak Blvd, Ste. 1400  
Houston, TX 77056

To learn about future public  
meetings (concerning your  
drinking water) or to request to  
schedule one, please call us at  
(281) 367-5511.

**En Español**

*Este reporte incluye informacion  
importante sobre el agua para  
tomar. Para asistencia en  
español, favor de llamar al telefono  
(281) 367-5511.*



2020  
**Annual Drinking  
Water  
Quality Report**

(Consumer Confidence Report)



Montgomery County MUD No. 95  
PWS ID#: 1700779

**Our Drinking Water Meets or Exceeds All Federal  
and State Drinking Water Requirements**

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required testing. We hope this information helps you become more knowledgeable about what's in your drinking water.

**Information about your Drinking Water**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

**ALL drinking water may contain contaminants**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please call (281) 367-5511.

**Special Notice for the Elderly, Infants,  
Cancer Patients, People with HIV/AIDS or  
Other Immune Problems**

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly or immuno-compromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk for infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline: (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

## Where Do We Get Our Water?

Our drinking water is obtained from ground water and surface water sources. Montgomery County Municipal Utility District No. 15 (PWS # 1700118) provides us ground water from the Evangeline Aquifer from wells located in Montgomery County. The City of Conroe provides us surface water from Lake Conroe in Montgomery County. The TCEQ has completed a Source Water Assessment for all drinking water systems that own their sources. The report describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The system(s) from which we purchase our water received our water received the assessment report. For more information on source water assessments and protections efforts at our system, please contact John Montgomery of our Regulatory Compliance Department at (281) 367-5511.

## About the Tables

EPA requires water systems to test for more than 90 contaminants in drinking water. The data tables in this report contain all of the regulated contaminants detected in your water, which are below state and federal allowed levels. The state of Texas allows us to monitor for some contaminants less than once per year because the concentrations do not change frequently. Definitions and abbreviations are provided below and sources of detected contaminants in this report follow the tables.

### Definitions and Abbreviations

Action Level Goal (ALG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Avg	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level Goal or MCL	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum Contaminant Level or MCL	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum residual disinfectant level goal or MRDLG	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Maximum residual disinfectant level or MRDL	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
mrem	millirems per year (a measure of radiation absorbed by the body)
na	not applicable.
ND	non-detect. This Indicates the contaminant was not detected in the sample. If any contaminant was present it was below the low-end detection limit for the laboratory test.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT	A required process intended to reduce the level of a contaminant in drinking water.

## Water Loss

In the water loss audit submitted to the Texas Water Development Board for the time period of Jan-Dec 2020, our system lost an estimated 2% of the total water produced. If you have any questions about the water loss audit please call (281) 367-5511.

**Information for Montgomery County MUD No. 95**

**Maximum Residual Disinfectant Level**

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Units	Violation
2020	Chlorine Residual (Free)	1.06	0.30	2.90	4	4	ppm	No

**Lead & Copper**

Year	Contaminant	The 90th Percentile	Number of Sites Exceeding AL	AL	MCLG	Units	Violation
2019	Lead	0.997	0	15	0	ppb	No
2019	Copper	0.083	0	1.3	1.3	ppm	No

**Disinfection Byproducts**

Year	Contaminant	Highest LRAA*	Range of Detected Levels	MCL	MCLG	Units	Violation
2020	Total Trihalomethanes (TTHM)	9	8.2 – 8.8	80	No goal for the total	ppb	No
2020	Haloacetic Acids (HAA5)	3	2.9 – 3.2	60	No goal for the total	ppb	No

\*LRAA is the locational running annual average or the highest average of sample results collected at a location over a year.

**From January to December 2020, Montgomery County MUD No. 95 received water through an open interconnect with Montgomery County MUD No. 15. The following table contains information from MCMUD No. 15's water supply.**

**Information from Montgomery County MUD No. 15 (Interconnect) (PWS # 1700118)**

**Inorganic Contaminants**

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2020	Barium	0.2	0.2 - 0.2	2	2	ppm	No
2020	Fluoride	0.3	0.3 - 0.3	4	4	ppm	No

**Radioactive Contaminants**

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2020	Beta/photon emitters	4.8	4.8 - 4.8	50	0	pCi/L*	No

\* EPA considers 50 pCi/L to be the level of concern for beta particles.

**From January to December 2020, Montgomery County MUD No. 95 received water through an open interconnect with the City of Conroe. The following table contains Information from City of Conroe water supply. (Interconnect) (PWS #1700001)**

**Information from the City of Conroe (Interconnect) (PWS # 1700001)**

**Inorganic Contaminants**

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2020	Barium	0.186	0.111 – 0.186	2	2	ppm	No
2020	Fluoride	0.2	0.12 – 0.3	4	4	ppm	No
2020	Nitrate	1	0 – 0.61	10	10	ppm	No
2018	Nitrite	0.01	0 – 0.01	1	1	ppm	No

**Radioactive Contaminants**

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2020	Combined Radium 226\228	1.5	1.5 – 1.5	5	0	pCi/L	No
2020	Beta/photon emitters	7.3	0 – 7.3	50	0	pCi/L	No
2020	Gross alpha excluding radon and uranium	3.8	0 – 3.8	15	0	pCi/L	No

\* EPA considers 50 pCi/L to be the level of concern for beta particles.

**Synthetic Organic Contaminants (including pesticides and herbicides)**

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2020	Di (2-ethylhexyl) phthalate	1.1	0 - 1.1	6	0	ppb	No

## Secondary Constituents

Many constituents (such as calcium, sodium or iron) which are often found in drinking water, can cause taste, color and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondary constituents are not required to be reported in this document, but they may greatly affect the appearance and taste of your water.

### **Public Notice: Monitoring and Reporting Violation**

Montgomery County MUD 95 - TX1700779 - received a violation for failure to submit data to the Texas Commission on Environmental Quality by the required reporting deadline for a nitrate monitoring. A sample for nitrate analysis was collected in the correct monitoring period and the laboratory result shows the contaminant was not detected. The violation was issued January 1, 2020 and was returned to compliance on March 31 2020 when results were submitted by the laboratory to the state.

## **Contaminant Sources**

<b>Contaminant</b>	<b>Source</b>
Barium	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Nitrite	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Combined Radium 226/228	Erosion of natural deposits
Beta/photon emitters	Decay of natural and man-made deposits.
Chlorine Residual	Water additive used to control microbes.
Lead	Corrosion of household plumbing systems; erosion of natural deposits.
Copper	Corrosion of household plumbing systems; erosion of natural deposits.
Xylenes	Discharge from petroleum factories; Discharge from chemical factories.

### **Outdoor Water Conservation Tips:**

- To keep your lawn healthy during the summer months - it only takes 1" of water a week.
- During the hot summer months, try to water in the early morning or late evening.
- In hot summer months, set your lawn mower to a higher setting, because taller grass helps hold in moisture. Cutting your grass too short can cause you to water more and can cause the grass to burn easier.
- Set your sprinkler system to a timer and adjust during the different seasons.

### **Indoor Water Conservation Tips:**

- To save on water and energy, always run your dishwasher with a full load.
- Take a shower instead of a bath.
- Check for leaks in your toilets and faucets. (A helpful hint is to schedule this for every six months when you are checking your smoke detectors.)
- When brushing your teeth, shaving, or washing your hands, only run the water when it is time to rinse.

## Welcome To EyeOnWater!

You now have more control of your water usage through EyeOnWater. EyeOnWater is a Badger Meter consumer portal application giving you the opportunity to monitor your water reading, water usage, set leak notifications, and more from your home computer, smart phone, and/or tablet. We encourage you sign up today because the water we save today can help save tomorrow.

Visit "<https://eyeonwater.net>" using a supported web browser. Sign up using your water bill and account number. For help creating your account please call 281-367-5511.