



# ANNUAL DRINKING WATER QUALITY REPORT

---

Harris County MUD 144  
TX1010923

**2023**

CALENDAR YEAR  
RESULTS



# ABOUT THIS REPORT

---

## **Our Drinking Water Meets or Exceeds All Federal and State Drinking Water Requirements.**

**Requirements.** This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required testing. We hope this information helps you become more knowledgeable about what's in your drinking water.

## **SPECIAL NOTICE FOR THE ELDERLY, INFANTS, CANCER PATIENTS, PEOPLE WITH HIV/AIDS OR OTHER IMMUNE PROBLEMS**

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly or immuno-compromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk for infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline: (800-426-4791).

### **En Español**

Este reporte incluye informacion importante sobre el agua para tomar.  
Para asistencia en español, favor de llamar al telefono (281) 367-5511.

# WHERE DO WE GET OUR WATER?

## HARRIS COUNTY MUD 144 WATER SOURCES

Harris County MUD 144 receives groundwater from the district wells and through an open interconnect with Harris County MUD 70. The district also received surface water from the Trinity River through an open interconnect with West Harris County Regional Water Authority.



### **SURFACE WATER SOURCE**

TRINITY RIVER  
(LAKE LIVINGSTON)

Treated by the City of Houston.



### **GROUNDWATER SOURCE**

1 DISTRICT WELL  
(EVANGELINE AQUIFER)  
HARRIS COUNTY MUD 70 WELL

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

The Texas Commission on Environmental Quality (TCEQ) completed an assessment of your source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on the susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, please contact our Regulatory Compliance Department at (281) 367-5511 or [compliance@municipalops.com](mailto:compliance@municipalops.com).

## WATER CONSERVATION TIPS



### **OUTDOORS**

**SET SPRINKLER TIMER, ADJUST DURING DIFFERENT SEASONS**

#### **SUMMER LAWN CARE**

- WATER IN EARLY MORNING OR LATE EVENING
- SET MOWER TO HIGHER SETTING TALLER GRASS HOLDS IN MORE MOISTURE, AND REQUIRES LESS WATERING
- 1" OF WATER A WEEK KEEPS YOUR LAWN HEALTHY



### **INDOORS**

**TAKE A SHOWER INSTEAD OF A BATH**

**ALWAYS RUN YOUR CLOTHES WASHER AND DISHWASHER WITH A FULL LOAD**

**CHECK FOR LEAKS IN YOUR TOILETS AND FAUCETS EVERY SIX MONTHS**

**ONLY RUN WATER TO RINSE WHEN**

- BRUSHING TEETH
- SHAVING
- WASHING HANDS

# WATER QUALITY DATA

EPA requires water systems to test for more than 90 contaminants in drinking water. The data tables in this report contain all of the regulated contaminants detected in your water. The state of Texas allows us to monitor for some contaminants less than once per year because the concentrations do not change frequently. The year that each result was detected is indicated in the tables.

Definitions, abbreviations, and sources of detected contaminants can be found on the last page of this report.

## HARRIS COUNTY MUD 144 MONITORING RESULTS

### INORGANIC CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2023	Barium	0.0491	0.0491 - 0.0491	2	2	ppm	N
2023	Cyanide	50	50 - 50	200	200	ppb	N
2023	Fluoride	0.25	0.25 - 0.25	4	4	ppm	N
2023	Nitrate	1	0.64 - 0.64	10	10	ppm	N

### SYNTHETIC ORGANIC CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2023	Atrazine	0.11	0.11 - 0.11	3	3	ppb	N
2023	Simazine	0.11	0.11 - 0.11	4	4	ppb	N

### DISINFECTANT BYPRODUCTS

Year	Contaminant	Highest LRAA	Range of Detected Levels	MCL	MCLG	Units	Violation
2023	Haloacetic Acids (HAA5)	22	15.9 - 29.9	60	None	ppb	N
2023	Total Trihalomethanes (TTHM)	25	21.6 - 32.1	80	None	ppb	N

### DISINFECTANT RESIDUAL

Year	Disinfectant	Average Level	Range of Detected Levels	MRDL	MRDLG	Units	Violation
2023	Chloramines (Total Chlorine)	3.27	3.17 - 3.38	4	4	ppm	N

# HARRIS COUNTY MUD 144 MONITORING RESULTS, CONTINUED

## LEAD AND COPPER

Year	Contaminant	90th Percentile	Number of Sites Exceeding AL	AL	MCLG	Units	Violation
2023	Copper	0.128	0	1.3	1.3	ppm	N
2023	Lead	17.9	3	15	0	ppb	N

## RADIOACTIVE CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2020	Beta/photon emitters	5.2	5.2 - 5.2	50	0	pCi/L	N
2020	Combined Radium 226/228	1.5	1.5 - 1.5	5	0	pCi/L	N

## MONITORING RESULTS FROM UPSTREAM WATER SUPPLIES

Throughout 2023, Harris County MUD 144 received surface water through an open interconnect with West Harris County RWA (WHCRWA.) WHCRWA receives water from the City of Houston Acres Homes, East, and Northeast Water Purification Plants (Entry Points 003, 101 and 141). The following table contains information from these water supplies.

## INORGANIC CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2023	Arsenic	0.0032	0.0032 - 0.0032	10	0	ppb	N

## SYNTHETIC ORGANIC CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2023	Atrazine	0.29	0.17 - 0.29	3	3	ppb	N

## RADIOACTIVE CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2023	Combined Radium 226/228	2.8	2.8 - 2.8	5	0	pCi/L	N
2023	Uranium	0.0016	0.0016 - 0.0016	30	0	ug/L	N
2023	Beta/photon emitters	4.9	4.9 - 4.9	50	0	pCi/L	N

## TURBIDITY

Year	Contaminant	Highest Single Measurement	Lowest Monthly Percentage <0.3 NTU	MCL	MCLG	Units	Violation
2023	Turbidity	0.52	95.7%	TT	0	NTU	N

## MONITORING RESULTS FROM UPSTREAM WATER SUPPLIES

In 2023, Harris County MUD 144 received surface water through an emergency interconnect with Harris County MUD 70 in March 2023 and May 2023. The following table contains information on this water supply.

### INORGANIC CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2023	Barium	0.0605	0.0605 - 0.0605	2	2	ppm	N
2023	Cyanide	110	110 - 110	200	200	ppb	N
2023	Fluoride	0.22	0.22 - 0.22	4	4	ppm	N
2023	Nitrate	0.49	0.49 - 0.49	10	10	ppm	N

### SYNTHETIC ORGANIC CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2023	Atrazine	0.11	0.11 - 0.11	3	3	ppb	N
2023	Simazine	0.08	0.08 - 0.08	4	4	ppb	N

### RADIOACTIVE CONTAMINANTS

Year	Contaminant	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Units	Violation
2023	Beta Photon Emitters	5.2	5.2 - 5.2	50	0	pCi/L	N



# DRINKING WATER CONTAMINANTS

---

ALL DRINKING WATER MAY CONTAIN CONTAMINANTS. IN ORDER TO ENSURE THAT TAP WATER IS SAFE TO DRINK, EPA PRESCRIBES REGULATIONS WHICH LIMIT THE AMOUNT OF CERTAIN CONTAMINANTS IN WATER PROVIDED BY PUBLIC WATER SYSTEMS. FDA REGULATIONS ESTABLISH LIMITS FOR CONTAMINANTS IN BOTTLED WATER WHICH MUST PROVIDE THE SAME PROTECTION FOR PUBLIC HEALTH. CONTAMINANTS MAY BE FOUND IN DRINKING WATER THAT MAY CAUSE TASTE, COLOR, OR ODOR PROBLEMS. THESE TYPES OF PROBLEMS ARE NOT NECESSARILY CAUSES FOR HEALTH CONCERNS. FOR MORE INFORMATION ON TASTE, ODOR, OR COLOR OF DRINKING WATER, PLEASE CALL (281) 367-5511.

CONTAMINANTS THAT MAY BE PRESENT IN SOURCE WATER INCLUDE:

- MICROBIAL CONTAMINANTS, SUCH AS VIRUSES AND BACTERIA, WHICH MAY COME FROM SEWAGE TREATMENT PLANTS, SEPTIC SYSTEMS, AGRICULTURAL LIVESTOCK OPERATIONS, AND WILDLIFE.
- INORGANIC CONTAMINANTS, SUCH AS SALTS AND METALS, WHICH CAN BE NATURALLY-OCCURRING OR RESULT FROM URBAN STORM WATER RUNOFF, INDUSTRIAL OR DOMESTIC WASTEWATER DISCHARGES, OIL AND GAS PRODUCTION, MINING, OR FARMING.
- PESTICIDES AND HERBICIDES, WHICH MAY COME FROM A VARIETY OF SOURCES SUCH AS AGRICULTURE, URBAN STORM WATER RUNOFF, AND RESIDENTIAL USES.
- ORGANIC CHEMICAL CONTAMINANTS, INCLUDING SYNTHETIC AND VOLATILE ORGANIC CHEMICALS, WHICH ARE BY-PRODUCTS OF INDUSTRIAL PROCESSES AND PETROLEUM PRODUCTION, CAN ALSO COME FROM GAS STATIONS, URBAN STORM WATER RUNOFF, AND SEPTIC SYSTEMS.
- RADIOACTIVE CONTAMINANTS, WHICH CAN BE NATURALLY-OCCURRING OR BE THE RESULT OF OIL AND GAS PRODUCTION AND MINING ACTIVITIES.

## ARSENIC

THIS DISTRICT'S DRINKING WATER CONTAINS LOW LEVELS OF ARSENIC, WHICH IS BELOW THE STATE AND FEDERAL ACTION LEVELS. EPA'S STANDARD BALANCES ARSENIC'S POSSIBLE HEALTH EFFECTS AGAINST THE COSTS OF REMOVING IT FROM DRINKING WATER. EPA CONTINUES TO RESEARCH THE HEALTH EFFECTS OF LOW LEVELS OF ARSENIC, WHICH IS A MINERAL KNOWN TO CAUSE CANCER IN HUMANS AT HIGH CONCENTRATIONS AND IS LINKED TO OTHER HEALTH EFFECTS SUCH AS SKIN DAMAGE AND CIRCULATORY PROBLEMS.

## LEAD

IF PRESENT, ELEVATED LEVELS OF LEAD CAN CAUSE SERIOUS HEALTH PROBLEMS, ESPECIALLY FOR PREGNANT WOMEN AND YOUNG CHILDREN. LEAD IN DRINKING WATER IS PRIMARILY FROM MATERIALS AND COMPONENTS ASSOCIATED WITH SERVICE LINES AND IN-HOME PLUMBING. THE HARRIS COUNTY MUD 144 IS RESPONSIBLE FOR PROVIDING HIGH-QUALITY DRINKING WATER BUT CANNOT CONTROL THE VARIETY OF MATERIALS USED IN IN-HOME PLUMBING COMPONENTS. WHEN WATER IN YOUR HOME PLUMBING HAS BEEN SITTING FOR SEVERAL HOURS, YOU CAN MINIMIZE THE POTENTIAL FOR LEAD EXPOSURE BY FLUSHING YOUR TAP FOR 30 SECONDS TO TWO MINUTES BEFORE USING WATER FOR DRINKING OR COOKING. IF YOU ARE CONCERNED ABOUT LEAD IN YOUR WATER, YOU MAY WISH TO HAVE YOUR WATER TESTED. INFORMATION ON LEAD IN DRINKING WATER, TESTING METHODS, AND STEPS YOU CAN TAKE TO MINIMIZE EXPOSURE IS AVAILABLE FROM THE SAFE DRINKING WATER HOTLINE (800.426.4791) OR AT [EPA.GOV/SAFEWATER/LEAD](http://EPA.GOV/SAFEWATER/LEAD).

## TURBIDITY

TURBIDITY HAS NO HEALTH EFFECTS. HOWEVER, TURBIDITY CAN INTERFERE WITH DISINFECTION AND PROVIDE A MEDIUM FOR MICROBIAL GROWTH. TURBIDITY MAY INDICATE THE PRESENCE OF DISEASE-CAUSING ORGANISMS. THESE ORGANISMS INCLUDE BACTERIA, VIRUSES, AND PARASITES THAT CAN CAUSE SYMPTOMS SUCH AS NAUSEA, CRAMPS, DIARRHEA, AND ASSOCIATED HEADACHES.

## SECONDARY CONSTITUENTS

MANY CONSTITUENTS (SUCH AS CALCIUM, SODIUM, OR IRON) WHICH ARE OFTEN FOUND IN DRINKING WATER, CAN CAUSE TASTE, COLOR, AND ODOR PROBLEMS. THE TASTE AND ODOR CONSTITUENTS ARE CALLED SECONDARY CONSTITUENTS AND ARE REGULATED BY THE STATE OF TEXAS, NOT THE EPA. THESE CONSTITUENTS ARE NOT CAUSES FOR HEALTH CONCERN. THEREFORE, SECONDARY CONSTITUENTS ARE NOT REQUIRED TO BE REPORTED IN THIS DOCUMENT, BUT THEY MAY GREATLY AFFECT THE APPEARANCE AND TASTE OF YOUR WATER.

# CONTAMINANT SOURCES

Contaminant	Source
Arsenic	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Atrazine	Runoff from herbicide used on row crops.
Barium	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Beta/ photon Emitters	Decay of natural and man-made deposits.
Chloramine Residual	Water additive used to control microbes.
Copper	Corrosion of household plumbing systems; erosion of natural deposits.
Combined Radium	Erosion of natural deposits.
Cyanide	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories.
Fluoride	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Gross Alpha emitters	Erosion of natural deposits.
Lead	Corrosion of household plumbing systems; erosion of natural deposits.
Nitrate	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Simazine	Herbicide runoff.
Total Trihalomethanes (TTHM)	By-product of drinking water disinfection.
Total Haloacetic Acids (HAA5)	By-product of drinking water disinfection.
Turbidity	Soil runoff.
Uranium	Erosion of natural deposits.

## PUBLIC INPUT OPPORTUNITY

YOUR WATER BOARD MEETS AT 8:45 AM ON THE THIRD MONDAY OF THE MONTH AT 18310 SANTOLINA LANE, KATY, TEXAS 77449.

TO LEARN ABOUT FUTURE PUBLIC MEETINGS CONCERNING YOUR DRINKING WATER, OR TO REQUEST TO SCHEDULE ONE, PLEASE CALL US AT 281-367-5511.



# DEFINITIONS AND ABBREVIATIONS

Action Level Goal (ALG)	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Avg	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment	A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level Goal or MCL	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum Contaminant Level or MCL	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum residual disinfectant level goal or MRDLG	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Maximum residual disinfectant level or MRDL	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
mrem	millirems per year (a measure of radiation absorbed by the body)
na	not applicable.
ND	non-detect. Indicates a contaminant was not detected in the sample. If contaminant was present it was below the detection limit for the laboratory test.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT	Required process intended to reduce the level of a contaminant in drinking water.

## CONTACT US

**QUESTIONS ABOUT THIS REPORT OR YOUR WATER QUALITY? PLEASE EMAIL COMPLIANCE@MUNICIPALOPS.COM OR CALL 281-367-5511 TO SPEAK WITH A MEMBER OF OUR REGULATORY COMPLIANCE TEAM.**