



Edit DMR

Collapse Header

Permit

Permit ID: TX0135976
Permittee: MEYER RANCH MUD OF COMAL COUNTY
Facility: MEYER RANCH MUD WWTP

Major:
Permittee Address: 901 S MO PAC EXPY STE 225
 AUSTIN, TX 78746
Facility Location: 1941 S CRANES MILL RD
 CITY OF NEW BRAUNFELS, TX 78132
Discharge: A - DOMESTIC FACILITY - 001

Permitted Feature: 001 - External Outfall

DMR Due Date: 03/20/22

Report Dates & Status

Monitoring Period: From 02/01/22 to 02/28/22

Status: **NetDMR Validated**

Principal Executive Officer

First Name:

Last Name:

Title:

Telephone:

No Data Indicator (NODI)

Form NODI:

Parameter		NODI	Quantity or Loading			Quality or Concentration				# of Ex.	Freq. of Analysis	Smpl. Type
Code	Name		Value 1	Value 2	Units	Value 1	Value 2	Value 3	Units			
00300	Oxygen, dissolved [DO]	Smpl.				= <input type="text" value="5.06"/>			mg/L <input type="text"/>	<input type="text" value="0"/>	<input type="text" value="01/07"/>	<input type="text" value="GR"/>
1 - Effluent Gross												
Season: 0		Req.				>=4.0 Minimum			Milligrams per Liter		Weekly	GRAB
NODI: <input type="text"/>		NODI				<input type="text"/>						
00400	pH	Smpl.				= <input type="text" value="7.24"/>		= <input type="text" value="7.4"/>	SU <input type="text"/>	<input type="text" value="0"/>	<input type="text" value="01/07"/>	<input type="text" value="GR"/>
1 - Effluent Gross												
Season: 0		Req.				>=6.0 Minimum		<=9.0 Maximum	Standard Units		Monthly	GRAB
NODI: <input type="text"/>		NODI				<input type="text"/>		<input type="text"/>				
00530	Solids, total suspended	Smpl.	< <input type="text" value="0.443"/>		lb/d <input type="text"/>		< <input type="text" value="1.0"/>	< <input type="text" value="1.0"/>	mg/L <input type="text"/>	<input type="text" value="0"/>	<input type="text" value="01/07"/>	<input type="text" value="GR"/>
1 - Effluent Gross												
Season: 0		Req.	<=6.3 Daily Average		Pounds per Day		<=5.0 Daily Average	<=30.0 Single Grab	Milligrams per Liter		Weekly	GRAB
NODI: <input type="text"/>		NODI	<input type="text"/>				<input type="text"/>	<input type="text"/>				
00600	Nitrogen, total [as N]	Smpl.	= <input type="text" value="2.674"/>		lb/d <input type="text"/>		= <input type="text" value="6.01"/>	= <input type="text" value="7.43"/>	mg/L <input type="text"/>	<input type="text" value="0"/>	<input type="text" value="01/07"/>	<input type="text" value="GR"/>
1 - Effluent Gross												
Season: 0		Req.	<=10.0 Daily Average		Pounds per Day		<=8.0 Daily Average	Req Mon Single Grab	Milligrams per Liter		Weekly	GRAB

Parameter		NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Freq. of Analysis	Smpl. Type
Code ▲	Name		Value 1	Value 2	Units	Value 1	Value 2	Value 3			
NODI:		NODI									
00610	Nitrogen, ammonia total [as N]	Smpl.	= ▼ 0.188		lb/d ▼	= ▼ 0.419	= ▼ 0.978	mg/L ▼	0	01/07 ▼	GR ▼
1 - Effluent Gross											
Season: 0		Req.	<=2.5 Daily Average		Pounds per Day	<=2.0 Daily Average	<=15.0 Single Grab	Milligrams per Liter		Weekly	GRAB
NODI:		NODI									
00665	Phosphorus, total [as P]	Smpl.	< ▼ 0.00563		lb/d ▼	< ▼ 0.0127	= ▼ 0.0186	mg/L ▼	0	01/07 ▼	GR ▼
1 - Effluent Gross											
Season: 0		Req.	<=0.63 Daily Average		Pounds per Day	<=0.5 Daily Average	<=3.0 Single Grab	Milligrams per Liter		Weekly	GRAB
NODI:		NODI									
50050	Flow, in conduit or thru treatment plant	Smpl.	= ▼ 0.051036	= ▼ 0.061	MGD ▼				0	99/99 ▼	TM ▼
1 - Effluent Gross											
Season: 0		Req.	<=0.15 Daily Average	Req Mon Daily Maximum	Million Gallons per Day					Continuous	TOTALZ
NODI:		NODI									
51040	E. coli	Smpl.				= ▼ 1.19	= ▼ 7.4	MPN/100mL ▼	0	05/WK ▼	GR ▼
1 - Effluent Gross											
Season: 0		Req.				<=126.0 Daily Average	<=399.0 Single Grab	Most Probable Number (MPN) per 100ml		Five Per Week	GRAB
NODI:		NODI									
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.	< ▼ 0.898		lb/d ▼	< ▼ 2.03	< ▼ 2.03	ug/L ▼	0	01/07 ▼	GR ▼
1 - Effluent Gross											
Season: 0		Req.	<=6.3 Daily Average		Pounds per Day	<=5.0 Daily Average	<=30.0 Single Grab	Micrograms per Liter		Weekly	GRAB
NODI:		NODI									

Edit Check Errors

No results.

DMR Comments

INTERIM PHASE II EFFECTIVE ON 03/01/2021 AND LASTING THROUGH THE COMPLETION OF EXPANSION TO 0.39 MGD.

Comments

Attachments

No results.

Report Last Saved By

User: deena@nwdls.com

Name: Deena Higginbotham
E-Mail: deena@nwdls.com
Date/Time: 03/17/22 6:07 CDT