



Edit DMR

Collapse Header

Permit

Permit ID: TX0135976
Permittee: MEYER RANCH MUD OF COMAL COUNTY
Facility: MEYER RANCH MUD WWTP

Major:
Permittee Address: 901 S MO PAC EXPY STE 225
 AUSTIN, TX 78746
Facility Location: 1941 S CRANES MILL RD
 CITY OF NEW BRAUNFELS, TX 78132
Discharge: A - DOMESTIC FACILITY - 001

Permitted Feature: 001 - External Outfall

DMR Due Date: 04/20/22

Report Dates & Status

Monitoring Period: From 03/01/22 to 03/31/22

Status: NetDMR Validated

Principal Executive Officer

First Name:

Last Name:

Title:

Telephone:

No Data Indicator (NODI)

Form NODI:

Parameter		NODI	Quantity or Loading			Quality or Concentration				# of Ex.	Freq. of Analysis	Smpl. Type
Code	Name		Value 1	Value 2	Units	Value 1	Value 2	Value 3	Units			
00300	Oxygen, dissolved [DO]	Smpl.				= <input type="text" value="6.46"/>			mg/L <input type="text"/>	<input type="text" value="0"/>	<input type="text" value="01/07"/>	<input type="text" value="GR"/>
1 - Effluent Gross												
Season: 0		Req.				>= 4.0 Minimum			Milligrams per Liter		Weekly	GRAB
NODI: <input type="text"/>		NODI				<input type="text"/>						
00400	pH	Smpl.				= <input type="text" value="7.34"/>		= <input type="text" value="7.75"/>	SU <input type="text"/>	<input type="text" value="0"/>	<input type="text" value="01/07"/>	<input type="text" value="GR"/>
1 - Effluent Gross												
Season: 0		Req.				>= 6.0 Minimum		<= 9.0 Maximum	Standard Units		Monthly	GRAB
NODI: <input type="text"/>		NODI				<input type="text"/>		<input type="text"/>				
00530	Solids, total suspended	Smpl.	< <input type="text" value="0.471"/>		lb/d <input type="text"/>		< <input type="text" value="1.14"/>	= <input type="text" value="1.68"/>	mg/L <input type="text"/>	<input type="text" value="0"/>	<input type="text" value="01/07"/>	<input type="text" value="GR"/>
1 - Effluent Gross												
Season: 0		Req.	<= 6.3 Daily Average		Pounds per Day		<= 5.0 Daily Average	<= 30.0 Single Grab	Milligrams per Liter		Weekly	GRAB
NODI: <input type="text"/>		NODI	<input type="text"/>				<input type="text"/>	<input type="text"/>				
00600	Nitrogen, total [as N]	Smpl.	= <input type="text" value="2.624"/>		lb/d <input type="text"/>		= <input type="text" value="7.59"/>	= <input type="text" value="12.07"/>	mg/L <input type="text"/>	<input type="text" value="0"/>	<input type="text" value="01/07"/>	<input type="text" value="GR"/>
1 - Effluent Gross												
Season: 0		Req.	<= 10.0 Daily Average		Pounds per Day		<= 8.0 Daily Average	Req Mon Single Grab	Milligrams per Liter		Weekly	GRAB

Parameter		NODI	Quantity or Loading			Quality or Concentration			# of Ex.	Freq. of Analysis	Smpl. Type
Code ▲	Name		Value 1	Value 2	Units	Value 1	Value 2	Value 3			
NODI:		NODI									
00610	Nitrogen, ammonia total [as N]	Smpl.	< ▼ 0.611		lb/d ▼	< ▼ 1.7	= ▼ 9.92	mg/L ▼	0	01/07 ▼	GR ▼
1 - Effluent Gross											
Season: 0		Req.	<= 2.5 Daily Average		Pounds per Day	<= 2.0 Daily Average		<= 15.0 Single Grab	Milligrams per Liter	Weekly	GRAB
NODI:		NODI									
00665	Phosphorus, total [as P]	Smpl.	= ▼ 0.0073		lb/d ▼	= ▼ 0.0177	= ▼ 0.0232	mg/L ▼	0	01/07 ▼	GR ▼
1 - Effluent Gross											
Season: 0		Req.	<= 0.63 Daily Average		Pounds per Day	<= 0.5 Daily Average		<= 3.0 Single Grab	Milligrams per Liter	Weekly	GRAB
NODI:		NODI									
50050	Flow, in conduit or thru treatment plant	Smpl.	= ▼ 0.049097	= ▼ 0.071	MGD ▼				0	99/99 ▼	TM ▼
1 - Effluent Gross											
Season: 0		Req.	<= 0.15 Daily Average		Req Mon Daily Maximum	Million Gallons per Day				Continuous	TOTALZ
NODI:		NODI									
51040	E. coli	Smpl.				< ▼ 1.0	< ▼ 1.0	MPN/100mL ▼	0	05/WK ▼	GR ▼
1 - Effluent Gross											
Season: 0		Req.				<= 126.0 Daily Average		<= 399.0 Single Grab	Most Probable Number (MPN) per 100ml	Five Per Week	GRAB
NODI:		NODI									
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.	< ▼ 0.889		lb/d ▼	< ▼ 2.18	< ▼ 2.4	ug/L ▼	0	01/07 ▼	GR ▼
1 - Effluent Gross											
Season: 0		Req.	<= 6.3 Daily Average		Pounds per Day	<= 5.0 Daily Average		<= 30.0 Single Grab	Micrograms per Liter	Weekly	GRAB
NODI:		NODI									

Edit Check Errors

No results.

DMR Comments

INTERIM PHASE II EFFECTIVE ON 03/01/2021 AND LASTING THROUGH THE COMPLETION OF EXPANSION TO 0.39 MGD.

Comments

Attachments

No results.

Report Last Saved By

User: deena@nwdls.com

Name: Deena Higginbotham
E-Mail: deena@nwdls.com
Date/Time: 04/18/22 7:49 CDT