

DMR Copy of Record

Permit			
Permit #:	TX0135976	Permittee:	MEYER RANCH MUD OF COMAL COUNTY
Major:	No	Permittee Address:	901 S MO PAC EXPY STE 225 AUSTIN, TX 78746
Permitted Feature:	001 External Outfall	Discharge:	001-A DOMESTIC FACILITY - 001
		Facility:	MEYER RANCH MUD WWTP
		Facility Location:	1941 S CRANES MILL RD CITY OF NEW BRAUNFELS, TX 78132

Report Dates & Status			
Monitoring Period:	From 04/01/23 to 04/30/23	DMR Due Date:	05/20/23
		Status:	NetDMR Validated

Considerations for Form Completion
 INTERIM I PHASE (RENAMED IN MINOR AMENDMENT) EFFECTIVE 03/01/21 AND LASTING THROUGH THE COMPLETION OF EXPANSION TO 0.30 MGD FACILITY.

Principal Executive Officer			
First Name:		Title:	
Last Name:		Telephone:	

No Data Indicator (NODI)
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	5.96									19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	>=	4.0 MINIMUM									19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.37					=	7.74		12 - SU	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	>=	6.0 MINIMUM				<=	9.0 MAXIMUM		12 - SU	01/30 - Monthly		GR - GRAB		
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	0.302			26 - lb/d		<	1.0	<	1.0	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	6.3 DAILY AV			26 - lb/d		<=	5.0 DAILY AV	<=	30.0 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample	=	3.47			26 - lb/d		=	6.14	=	9.79	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	10.0 DAILY AV			26 - lb/d		<=	8.0 DAILY AV		Req Mon SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.0151			26 - lb/d		<	0.05	<	0.05	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	2.5 DAILY AV			26 - lb/d		<=	2.0 DAILY AV	<=	15.0 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	=	0.0156			26 - lb/d		=	0.0477	=	0.137	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	0.63 DAILY AV			26 - lb/d		<=	0.5 DAILY AV	<=	3.0 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.0698	=	0.102	03 - MGD							0	99/99 - Continuous	TM - TOTALZ
					Permit Req.	<=	0.15 DAILY AV			Req Mon DAILY MX	03 - MGD							99/99 - Continuous	TM - TOTALZ
					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample	=						=	1.23	=	6.3	30 - MPN/100mL	0	05/WK - Five Per Week	GR - GRAB
					Permit Req.						<=	126.0 DAILY AV	<=	399.0 SINGGRAB	30 - MPN/100mL	05/WK - Five Per Week		GR - GRAB	
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	0.613			26 - lb/d		<	2.03	<	2.03	28 - ug/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	6.3 DAILY AV			26 - lb/d		<=	5.0 DAILY AV	<=	30.0 SINGGRAB	28 - ug/L		01/07 - Weekly	GR - GRAB
					Value NODI														

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments
 No attachments.

Report Last Saved By
 MEYER RANCH MUD OF COMAL COUNTY

User: deena@nwdls.com

Name: Deena Higginbotham
E-Mail: deena@nwds.com
Date/Time: 2023-05-19 09:31 (Time Zone: -05:00)

Report Last Signed By

User: jtmontgomery
Name: John Montgomery
E-Mail: jmontgomery@municipalops.com
Date/Time: 2023-05-19 22:35 (Time Zone: -05:00)