

Parameter		NODI	Quantity or Loading			Quality or Concentration				# of Ex.	Freq. of Analysis	Smpl. Type		
Code ▲	Name		Value 1	Value 2	Units	Value 1	Value 2	Value 3	Units					
00610	Nitrogen, ammonia total [as N]	Smpl.	= ▼	<input type="text" value="0.0223"/>	lb/d ▼		= ▼	<input type="text" value="0.06"/>	= ▼	<input type="text" value="0.1"/>	mg/L ▼	<input type="text" value="0"/>	01/07 ▼	GR ▼
1 - Effluent Gross														
Season: 0														
Req.		<= 2.5 Daily Average		Pounds per Day		<= 2.0 Daily Average	<= 15.0 Single Grab	Milligrams per Liter		Weekly	GRAB			
NODI: <input type="text"/>		NODI	<input type="text"/>			<input type="text"/>	<input type="text"/>							
00665	Phosphorus, total [as P]	Smpl.	= ▼	<input type="text" value="0.0316"/>	lb/d ▼		= ▼	<input type="text" value="0.0886"/>	= ▼	<input type="text" value="0.314"/>	mg/L ▼	<input type="text" value="0"/>	01/07 ▼	GR ▼
1 - Effluent Gross														
Season: 0														
Req.		<= 0.63 Daily Average		Pounds per Day		<= 0.5 Daily Average	<= 3.0 Single Grab	Milligrams per Liter		Weekly	GRAB			
NODI: <input type="text"/>		NODI	<input type="text"/>			<input type="text"/>	<input type="text"/>							
50050	Flow, in conduit or thru treatment plant	Smpl.	= ▼	<input type="text" value="0.080467"/>	= ▼	<input type="text" value="0.103"/>	MGD ▼					<input type="text" value="0"/>	99/99 ▼	TM ▼
1 - Effluent Gross														
Season: 0														
Req.		<= 0.15 Daily Average	Req Mon	Daily Maximum	Million Gallons per Day					Continuous	TOTALZ			
NODI: <input type="text"/>		NODI	<input type="text"/>	<input type="text"/>										
51040	E. coli	Smpl.					= ▼	<input type="text" value="1.0"/>	= ▼	<input type="text" value="1.0"/>	MPN/100mL ▼	<input type="text" value="0"/>	05/WK ▼	GR ▼
1 - Effluent Gross														
Season: 0														
Req.						<= 126.0 Daily Average	<= 399.0 Single Grab	Most Probable Number (MPN) per 100ml		Five Per Week	GRAB			
NODI: <input type="text"/>		NODI				<input type="text"/>	<input type="text"/>							
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.	= ▼	<input type="text" value="0.754"/>	lb/d ▼		< ▼	<input type="text" value="2.03"/>	< ▼	<input type="text" value="2.03"/>	mg/L ▼	<input type="text" value="0"/>	01/07 ▼	GR ▼
1 - Effluent Gross														
Season: 0														
Req.		<= 6.3 Daily Average		Pounds per Day		<= 5.0 Daily Average	<= 30.0 Single Grab	Milligrams per Liter		Weekly	GRAB			
NODI: <input type="text"/>		NODI	<input type="text"/>			<input type="text"/>	<input type="text"/>							

Edit Check Errors

No results.

DMR Comments

PER NOC INTERIM I PHASE (RENAMED IN MINOR AMENDMENT) EFFECTIVE 03/01/21 AND LASTING THROUGH THE COMPLETION OF EXPANSION TO 0.30 MGD FACILITY.

Comments

Attachments

No results.

Report Last Saved By

User: deena@nwdls.com
Name: Deena Higginbotham
E-Mail: deena@nwdls.com
Date/Time: 07/14/23 4:19 CDT