

Parameter		NODI	Quantity or Loading			Quality or Concentration				# of Ex.	Freq. of Analysis	Smpl. Type
Code ▲	Name		Value 1	Value 2	Units	Value 1	Value 2	Value 3	Units			
00610	Nitrogen, ammonia total [as N]	Smpl.	= ▼ 0.00533		lb/d ▼	= ▼ 0.0515	= ▼ 0.0558	mg/L ▼	0	01/07 ▼	GR ▼	
1 - Effluent Gross												
Season: 0		Req.	<= 2.5 Daily Average		Pounds per Day	<= 2.0 Daily Average		<= 15.0 Single Grab	Milligrams per Liter	Weekly	GRAB	
NODI: ▼		NODI	▼			▼	▼					
00665	Phosphorus, total [as P]	Smpl.	= ▼ 0.0442		lb/d ▼	= ▼ 0.499	= ▼ 0.736	mg/L ▼	0	01/07 ▼	GR ▼	
1 - Effluent Gross												
Season: 0		Req.	<= 0.63 Daily Average		Pounds per Day	<= 0.5 Daily Average		<= 3.0 Single Grab	Milligrams per Liter	Weekly	GRAB	
NODI: ▼		NODI	▼			▼	▼					
50050	Flow, in conduit or thru treatment plant	Smpl.	= ▼ 0.071467	= ▼ 0.095	MGD ▼				0	99/99 ▼	TM ▼	
1 - Effluent Gross												
Season: 0		Req.	<= 0.15 Daily Average	Req Mon Daily Maximum	Million Gallons per Day					Continuous	TOTALZ	
NODI: ▼		NODI	▼	▼								
51040	E. coli	Smpl.				= ▼ 1.17	= ▼ 17.5	MPN/100mL ▼	0	05/07 ▼	GR ▼	
1 - Effluent Gross												
Season: 0		Req.				<= 126.0 Daily Average		<= 399.0 Single Grab	Most Probable Number (MPN) per 100ml	Five Per Week	GRAB	
NODI: ▼		NODI				▼	▼					
80082	BOD, carbonaceous [5 day, 20 C]	Smpl.	= ▼ 0.219		lb/d ▼	= ▼ 2.12	= ▼ 2.4	mg/L ▼	0	01/07 ▼	GR ▼	
1 - Effluent Gross												
Season: 0		Req.	<= 6.3 Daily Average		Pounds per Day	<= 5.0 Daily Average		<= 30.0 Single Grab	Milligrams per Liter	Weekly	GRAB	
NODI: ▼		NODI	▼			▼	▼					

Edit Check Errors

No results.

DMR Comments

PER NOC INTERIM I PHASE (RENAMED IN MINOR AMENDMENT) EFFECTIVE 03/01/21 AND LASTING THROUGH THE COMPLETION OF EXPANSION TO 0.30 MGD FACILITY.

Comments

Attachments

No results.

Report Last Saved By

User: deena@nwdls.com
Name: Deena Higginbotham
E-Mail: deena@nwdls.com
Date/Time: 10/12/23 9:01 CDT