

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

<b>Permit</b>		<b>Permit #:</b> TX0135976		<b>Permittee:</b> MEYER RANCH MUD OF COMAL COUNTY		<b>Facility:</b> MEYER RANCH MUD WWTP													
<b>Major:</b> No		<b>Permittee Address:</b> 901 S MO PAC EXPY STE 225 AUSTIN, TX 78746		<b>Facility Location:</b> 1941 S CRANES MILL RD CITY OF NEW BRAUNFELS, TX 78132															
<b>Permitted Feature:</b> 001 External Outfall		<b>Discharge:</b> 001-A DOMESTIC FACILITY - 001																	
<b>Report Dates &amp; Status</b>																			
<b>Monitoring Period:</b> From 08/01/24 to 08/31/24		<b>DMR Due Date:</b> 09/20/24		<b>Status:</b> NetDMR Validated															
<b>Considerations for Form Completion</b>																			
PER NOC INTERIM I PHASE (RENAMED IN MINOR AMENDMENT) EFFECTIVE 03/01/21 AND LASTING THROUGH THE COMPLETION OF EXPANSION TO 0.30 MGD FACILITY.																			
<b>Principal Executive Officer</b>																			
<b>First Name:</b>		<b>Title:</b>		<b>Telephone:</b>															
<b>Last Name:</b>																			
<b>No Data Indicator (NODI)</b>																			
<b>Form NODI:</b> --																			
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	4.6				=	4.6				19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	>=	4.0 MINIMUM								19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.4				=	8.0			12 - SU	0	01/30 - Monthly	GR - GRAB	
					Permit Req.	>=	6.0 MINIMUM							<=	9.0 MAXIMUM		12 - SU	01/30 - Monthly	GR - GRAB
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	0.079		26 - lb/d		=	1.0	=	1.0	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	6.3 DAILY AV		26 - lb/d		<=	5.0 DAILY AV	<=	30.0 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI														
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample	=	5.71		26 - lb/d		=	7.37	=	8.5	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	10.0 DAILY AV		26 - lb/d		<=	8.0 DAILY AV		Req Mon SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.08		26 - lb/d		=	0.11	=	0.18	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	2.5 DAILY AV		26 - lb/d		<=	2.0 DAILY AV	<=	15.0 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI														
X 00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	=	3.0		26 - lb/d		=	3.71	=	4.6	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	0.63 DAILY AV		26 - lb/d		<=	0.5 DAILY AV	<=	3.0 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.099	=	0.14	03 - MGD						0	99/99 - Continuous	TM - TOTALZ	
					Permit Req.	<=	0.15 DAILY AV		Req Mon DAILY MX	03 - MGD							99/99 - Continuous	TM - TOTALZ	
					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample	=					=	6.7	=	135.0	30 - MPN/100mL	0	05/WK - Five Per Week	GR - GRAB	
					Permit Req.	<=					<=	126.0 DAILY AV	<=	399.0 SINGGRAB	30 - MPN/100mL		05/WK - Five Per Week	GR - GRAB	
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	1.0		26 - lb/d		=	1.2	=	2.0	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	<=	6.3 DAILY AV		26 - lb/d		<=	5.0 DAILY AV	<=	30.0 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI														

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00665	Phosphorus, total [as P]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes
00665	Phosphorus, total [as P]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes
00665	Phosphorus, total [as P]	1 - Effluent Gross	Quantity or Loading Sample Value 1	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes

**Comments**

**Attachments**

No attachments.

**Report Last Saved By**

**MEYER RANCH MUD OF COMAL COUNTY**

User: LDELONG7  
Name: Lindsey DeLong  
E-Mail: compliance@municipalops.com  
Date/Time: 2024-09-20 11:52 (Time Zone: -05:00)

**Report Last Signed By**

User: LDELONG7  
Name: Lindsey DeLong  
E-Mail: compliance@municipalops.com  
Date/Time: 2024-09-20 11:52 (Time Zone: -05:00)